## E3S-CL

CSM\_E3S-CL\_DS\_E\_5\_3

# **Simply Set the Distance to Reliably Detect Workpieces of Various Colors**

- Reliable detection regardless of color or material. Black/white error of only 2% max. (E3S-CL1)
- Long sensing distance of 500 mm (E3S-CL2).
- Eliminates background influence.
   (Differential travel of only 2% max. with E3S-CL1.)
- Metal body with IP67 protection.
   Oil resistance (E3S-CL2).






Be sure to read *Safety Precautions* on page 7.

For the most recent information on models that have been certified for safety standards, refer to your OMRON website.

## **Ordering Information**



OMRON 1

## **Ratings and Specifications**


Sensing method		Distance-settable			
Item	Model	E3S-CL1	E3S-CL2		
Sensing distance		5 to 200 mm (white paper: 200 x 200 mm, setting distance: 200 mm)	5 to 500 mm (white paper: 200 x 200 mm, setting distance: 500 mm)		
Setting range		40 to 200 mm (white paper: 200 x 200 mm)	50 to 500 mm (white paper: 200 x 200 mm)		
Differential travel		2% max. of setting distance	10% max. of setting distance		
Reflectivity characteristics (black/white error) *1		2% max. of setting distance	10% max. of setting distance		
Light source (wavelength)		Red LED (700 nm)	Infrared LED (860 nm)		
Powe	r supply voltage	10 to 30 VDC; ripple: 10% max.			
Curre	nt consumption	35 mA max.	50 mA max.		
Contr	ol output	Load power supply voltage: 30 VDC max., Load current: 100 mA max. Residual voltage: NPN output: 1.2 V max. PNP output: 2 V max. Open collector output (NPN/PNP depending on model) Light-ON/Dark-ON selectable			
Prote	ction circuits	Power supply reverse polarity protection, Output short-	circuit protection, Mutual interference prevention		
Response time		Operate or reset: 1 ms max.	Operate or reset: 2 ms max.		
Distance setting		Six-turn endless adjustor with an indicator			
	ent illumination iver side)	Incandescent lamp: illumination on optical spot: 5,000 lx max. Sunlight: illumination on optical spot: 10,000 lx max.			
Ambie range	ent temperature	Operating: –25 to 55°C, Storage: –40 to 70°C (with no icing or condensation)			
Ambient humidity range		Operating: 35% to 85%, Storage: 35% to 95% (with no condensation)			
Insulation resistance		20 MΩ min. at 500 VDC			
Dielec	ctric strength	1,000 VAC, 50/60 Hz for 1 min			
Vibrat	tion resistance	Destruction: 10 to 55 Hz, 1.5-mm double amplitude for 2 hrs each in X, Y, and Z directions			
Shock resistance		Destruction: 500 m/s <sup>2</sup> 3 times each in X, Y, and Z directions			
Degre	e of protection	IP67 (IEC 60529), NEMA: 6P (indoors only) *2	IP67 (IEC 60529) (in-house standards: oil-resistant). NEMA: 6P (indoors only) *2		
Conne	ection method	Pre-wired (standard length: 2 m)			
Weigh	nt (packed state)	Approx. 170 g			
	Case	Zinc die-cast			
Ma-	Operation panel	PES (Polyether sulfone)			
teri- als	Lens	Methacrylic resin			
	Mounting bracket	Stainless steel (SUS304)			
Acces	ssories	Mounting bracket, 12 M4 hexagonal bolts (with spring a manual	and flat washers), Adjustment screwdriver, and Instruct		

<sup>\*1.</sup> Sensing distance error for standard white (90% reflective) and black (5% reflective) paper.
\*2. NEMA: National Electrical Manufacturers Association


## **Engineering Data (Reference value)**

## **Operating Range**

## E3S-CL1




## E3S-CL2




## **Sensing Object Size vs. Sensing Distance**

## E3S-CL1




## E3S-CL2




## **Spot Diameter vs. Sensing Distance**

## E3S-CL1




#### E3S-CL2




## Sensing Distance vs. Minimum Detectable Object Size

## E3S-CL1




## E3S-CL2




## **Sensing Object Angle Characteristics**


## E3S-CL1 Vertical




#### E3S-CL1 Horizontal



#### E3S-CL2 Vertical




#### **E3S-CL2 Horizontal**




## **Sensing Distance vs. Sensing Object Material**

## E3S-CL1


(Setting Distance of 200 mm using White Paper)



(Setting Distance of 100 mm using White Paper)




(Setting Distance of 40 mm using White Paper)




#### E3S-CL2


(Setting Distance of 500 mm using White Paper)



(Setting Distance of 300 mm using White Paper)




(Setting Distance of 50 mm using White Paper)




## **Close-range Characteristics**

## E3S-CL1



## E3S-CL2



## I/O Circuit Diagrams

## **NPN Output**


Model	Operation mode	Timing charts	Operation selector	Output circuit	
E3S-CL1	Light-ON	Incident light No incident light Operation ON indicator (orange) Output ON transistor OFF Load Operate (relay) Reset	L side (LIGHT ON)	Stability  Indicator (green)  Photo-electric sensor  NPN and PNP output transistor  NPN and PNP output selector  Output selector	
E3S-CL2	Dark-ON	Incident light No incident light Operation ON indicator (orange) Output transistor OFF Load Operate (relay) Reset	D side (DARK ON)	(orange) Main Output selector NPN output transistor ZD Blue 0 V  *Set the NPN and PNP output selector to NPN.	

## **PNP Output**

Model	Operation mode	Timing charts	Operation selector	Output circuit	
E3S-CL1 E3S-CL2	Light-ON	Incident light  No incident light  Operation ON indicator OFF (orange) OFF Output ON transistor OFF  Load Operate (relay) Reset	L side (LIGHT ON)	Stability Indicator (green) Photo- lectric Sensor (orange) Indicator (orange) Indicator (green)  NPN and PNP output transistor  NPN and PNP output selector  NPN and PNP output selector  Output selector	
	Dark-ON	Incident light No incident light Operation ON indicator (orange) Output ON transistor OFF Load Operate (relay) Reset	D side (DARK ON)	*Set the NPN and PNP output selector to PNP.	

## **Nomenclature**

## **Operation Panel**



## **Output Selector**

- 1. Set the selector to NPN for NPN output.
- 2. Set the selector to PNP for PNP output.

## **Operation Selector**

- 1. Set the selector to L-ON for ON light-ON operation.
- 2. Set the selector to D-ON for ON dark-ON operation.

## **Setting Distance Adjuster**

- The sensing distance will increase when the adjuster is turned clockwise (toward Max.) and will decrease when the knob is turn counterclockwise.
- The adjustment can be turned up to 6 times clockwise or counterclockwise to set the sensing distance. The number of turns will be displayed by the indicator.

## **Safety Precautions**

## Refer to Warranty and Limitations of Liability.



This product is not designed or rated for ensuring safety of persons either directly or indirectly. Do not use it for such purposes.



#### **Precautions for Correct Use**

Do not use the product in atmospheres or environments that exceed product ratings.

#### Designing

#### **Cable**


The E3S-CL2 uses an oil-resistive cord to ensure oil resistivity.

#### Mounting


#### **Mounting**

#### **Mounting Direction**


 Mount the Sensor so that the sensing face runs parallel to the surface of the object being detected as shown below, and not at an angle.




If detecting a shiny object, however, mount the Sensor so that the sensing face is at an angle of between 5° and 10° of the surface of the object being detected as shown below, and check to be sure that there is no interference from the background.




If stable operation is not possible near a mirror surface, mount the Sensor at an angle as shown below, and separate the Sensor as far as possible from the mirror surface.



• Mount the Sensor so that it is not aligned with the direction of movement of the sensing object, as shown below.



 Also, mount the Sensor so that it is not aligned with extreme changes in color or materials, as shown below.



 Mount the Sensor so that sunlight, fluorescent light, incandescent light, or other strong sources of light do not enter the directional angle of the Sensor.

#### **Precautions**

- When mounting the Sensor, do not hit the Sensor with a hammer, or the Sensor will lose its watertightness.
- Use M4 screws to mount the Sensor.
- The tightening torque of each screw must be 1.2 N⋅m maximum.

#### Others

#### Oil and Chemical Resistivity (E3S-CL2)

The E3S-CL2 was tested for resistance to the oils given in the following table. Refer to the information in the table when deciding which type of oil to use. However, performance may be affected by certain types of oil.


Test oil classification	Product name	Kinematic viscosity (mm²/s (cst)) at 40°C	рН	
Lubricating oil	Velocity No.3 (manufactured by Exx- on Mobil)	2.02		
Water insoluble machining oil	Yushiron Oil No. 2 ac (manufactured by Yushiro Chemical In- dustry Co., Ltd.)  Less than 10			
	Yushiroken EC50T-3 (manufactured by Yushiro Chemical In- dustry Co., Ltd.)		7 to 9.5	
Water soluble	Yushiron Lubic HWC68 (manufactured by Yushiro Chemical In- dustry Co., Ltd.)		7 to 9.9	
machining oil	Gryton 1700D (manufactured by Toho Chemical Industry Co., Ltd.)		7 to 9.2	
	Yushiroken S50N (manufactured by Yushiro Chemical In- dustry Co., Ltd.)		7 to 9.8	

Note: 1. The E3S-CL2 maintained a minimum insulation resistance of 100 M $\Omega$  after it was dipped in all the above oils at a temperature of 50°C for 240 hours

2. When using the E3S-CL2 in environments subject to oils other than those listed above, use the figures for kinematic viscosity and ph values from the table as general guidelines. Additives and other substances contained in oils may affect the E3S-CL2. Be sure to consider this before use.

## **Dimensions**

E3S-CL1



Note: The output selector, operation selector, and distance setting adjuster are located inside the cover.

-40 44.7

Detecting axis

**OMRON** 

## Terms and Conditions Agreement

#### Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

#### Warranties.

- (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.
- (b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE

PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warrantv.

See <a href="http://www.omron.com/global/">http://www.omron.com/global/</a> or contact your Omron representative for published information.

#### Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

### Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

### Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

#### Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

#### Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions. Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.

2020.3

In the interest of product improvement, specifications are subject to change without notice.

